

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date ~~12-3-10~~ 12-3-10 Time 3:00 p.m. Location 110 Scarbora

Please Circle Appropriate Action New Line Installation Line Repair Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed (YES NO)

Detailed summary of disinfection procedure used (Use back of page if needed)

Chlorine Residual Prior to Initial Flush

Date Time of Initial Flush Length of Time of Initial

Flush Chlorine Residual after Flush

Water Supply (WS) Project Number

FOR LINE REPAIRS:

Interruption of Water Service YES NO Number of Customers Affected 1

Main Size 6" PVL Repaired Under Pressure YES NO

For partially or fully de-watered mains

Was positive pressure maintained while a trench was opened and area cleaned YES NO

Time Water Main Valved Off (positive pressure removed) am pm

Nature of Leak or Break

replaced leaking service

Were State approved or AWWA Standards Followed (YES NO)

Detailed summary of repair procedure used (Use back of page if needed)

Replaced with copper

Was water main contaminated during the repair process? (YES NO)

Disinfection Procedure Calculations (Use back of page if needed)

Flushed line

Amount of Time Line Flushed Minutes
Residual mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected YES NO

Results**

**Attach copy of results to record)

Date Time Water Main Returned to Service

am pm

Additional Comments

84 PSI

See Photos

18 GPM

Aden - Tim - Bull

