

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 12-3-10 Time 3:00 p.m. Location 114 Sec:510

Please Circle Appropriate Action: New Line Installation / Line Repair Service Line

**NEW LINE INSTALLATION:**

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed)

Chlorine Residual Prior to Initial Flush

Date Time of Initial Flush Length of Time of Initial  
Flush Chlorine Residual after Flush

Water Supply (WS) Project Number

**FOR LINE REPAIRS:**

Interruption of Water Service YES ✓ NO Number of Customers Affected 1

Main Size 6" PVC Repaired Under Pressure YES NO

For partially or fully de-watered mains.

Was positive pressure maintained while a trench was opened and area cleaned? (YES ✓ NO)

Time Water Main Valved Off (positive pressure removed) am pm

Nature of Leak or Break

replaced leaking service

Were State approved or AWWA Standards Followed: YES NO

Detailed summary of repair procedure used (Use back of page if needed)

Replaced with copper  
Was water main contaminated during the repair process? (YES NO ✓)

Disinfection Procedure / Calculations (Use back of page if needed)

Flushed line

Amount of Time Line Flushed Minutes  
Residual mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected: YES NO  
(\*\* Attach copy of results to record)

Results\*\*

Date / Time Water Main Returned to Service am pm

Additional Comments

84 psi

2.20 cl<sup>2</sup>

Sec Photos

18 GPM

Adam-Tim-Bull

