FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 9-(-09 Time: 11.00 g.m. Location: 125 Reduced
Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line
NEW LINE INSTALLATION:
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of disinfection procedure used (Use back of page if needed):
Chlorine Residual Prior to Initial Flush: Date / Time of Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush:
Water Supply (WS) Project Number:
FOR LINE REPAIRS:
Interruption of Water Service: YES NONumber of CustomersAffected:
Main Size: 2" Repaired Under Pressure: YES NO
For partially or fully de-watered mains:
Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) Time Water Main Valved Off (positive pressure removed): am / pm
Nature of Leak or Break: Killed out old 3/4 Gglu
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of repair procedure used (Use back of page if needed):
4 Grlu Fed by 1/2" copper — cut copper and capped with 1/2" Fende and plug Was water main contaminated during the repair process? (YES / NO) Disinfection Procedure / Calculations (Use back of page if needed):
Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L
Bacteriological Sample Collected: YESNO Results**:
Date / Time Water Main Returned to Service: am / pm
Additional Comments:

Rev 01-21-09