

# FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 9/7/11 Time: 1:20<sup>Am</sup> to 4:30<sup>Am</sup> Location: 1418 Oakdale Hwy

Please Circle Appropriate Action: New Line Installation / Line Repair / (Service Line)

## NEW LINE INSTALLATION:

COPY

Were State approved or AWWA Standards Followed: (YES / NO)  
Detailed summary of disinfection procedure used (Use back of page if needed):

West  
Billy  
Adam  
Reed

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_  
Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial  
Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

## FOR LINE REPAIRS:

Interruption of Water Service: YES \_\_\_ NO ✓ Number of Customers Affected: 1

Main Size: 8" Repaired Under Pressure: YES ✓ NO \_\_\_

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

<sup>1</sup>Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

Corrosion blow off 8" Trans Water

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of repair procedure used (Use back of page if needed):

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Clean pipe used bleach on hand

Amount of Time Line Flushed: \_\_\_\_\_ Minutes

Ending Chlorine

Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES \_\_\_ NO \_\_\_

Results\*\*: \_\_\_\_\_

(\*\*Attach copy of results to record)

Date / Time Water Main Returned to Service: 9/7/11 4:15 am / pm

Additional Comments:

Flowing out 22 gal minute

60,000 Gallon  
According to WTP Reading