

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 3-14-12 Time: 9:30 Location: 143 Tinker Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed)

COPY

3-15-12

8

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 1

Main Size: 2" PVC Repaired Under Pressure: YES ☐ NO ☐

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed) _____ am / pm

Nature of Leak or Break:

leaking copper service

Were State approved or AWWA Standards Followed: YES / NO

Detailed summary of repair procedure used (Use back of page if needed):

Replaced copper service

Was water main contaminated during the repair process? (YES / NO) NO

Disinfection Procedure / Calculations (Use back of page if needed):

Flushed line

Amount of Time Line Flushed: 1 Minutes

Ending Chlorine 2.20

Residual: _____ mg/L

Bacteriological Sample Collected: YES ☐ NO ☐

Results**: _____

(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments: See Photos

Rev 01-21-09

13 GPM Before
17.5 GPM After

Adam
Billy
Bonnie

COPY