

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 3-12-12 Time: All Day Location: 144 Tinker Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

COPY

3-16-12
J

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 3

Main Size: 2" PUL Repaired Under Pressure: YES ☐ NO ☐

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed) _____ am / pm

Nature of Leak or Break:

leaking service

Were State approved or AWWA Standards Followed (YES / NO) YES

Detailed summary of repair procedure used (Use back of page if needed):

Replaced
leakings & changed
Saddle
Plastic service

Was water main contaminated during the repair process? (YES / NO) NO

Disinfection Procedure / Calculations (Use back of page if needed):

Flushed line

Amount of Time Line Flushed: 30 Minutes
Residual: _____ mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected: YES ☐ NO ☐
(**Attach copy of results to record)

Results**: _____

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

See Photos Throttled down valve to
a trickle, changed saddle, and replaced
Service

4-10-9