

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 12-28-11 Time: 9:00 Location: 170 Scott Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)  
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_  
Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial  
Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

COPY

Water Supply (WS) Project Number: \_\_\_\_\_

FOR LINE REPAIRS:

Interruption of Water Service: YES \_\_\_ NO ✓ Number of Customers Affected: 0

Main Size: 2" PUL Repaired Under Pressure: YES \_\_\_ NO \_\_\_

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

leaking vacant service

Were State approved or AWWA Standards Followed: (YES) NO) Replaced with  
Detailed summary of repair procedure used (Use back of page if needed): copper

Was water main contaminated during the repair process? (YES / NO) Flushed line  
Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: 1 Minutes Ending Chlorine 2.20  
Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES \_\_\_ NO \_\_\_ Results\*\*: \_\_\_\_\_  
(\*\*Attach copy of results to record)

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments: See Photos John Treu's old tap.

Rev 01-21-09

5 GPM leak Adam-Bull-Tim

Vacant

Copy