| FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR  |
|--|
| Date 9/18/05 Time: 6:45p Location: Powers Loup 177   |
| Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line   |
| NEW LINE INSTALLATION:   |
| Were State approved or AWWA Standards Followed: (YES / NO)<br>Detailed summary of disinfection procedure used (Use back of page if needed):  |
| Chlorine Residual Prior to Initial Flush: Length of Time of Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush:   |
| Water Supply (WS) Project Number:  |
| FOR LINE REPAIRS:  |
| Interruption of Water Service: YES / NO Number of CustomersAffected: 19  |
| Main Size: 4 PVC Repaired Under Pressure: YES NO   |
| For partially or fully de-watered mains:   |
| Was positive pressure maintained while a trench was opened and area cleaned? (YES)<br>NO)<br><sup>1</sup> Time Water Main Valved Off (positive pressure removed): <u>6.45</u> am pm  |
| Nature of Leak or Break:<br>4 Puc Selit  |
| Were State approved or AWWA Standards Followed: (YES/NO)<br>Detailed summary of repair procedure used (Use back of page if needed):<br>Replaced 52° fiece, Bleach Pipe Bands<br>Was water main contaminated during the repair process? (YES/NO)<br>Disinfection Procedure / Calculations (Use back of page if needed): |
| Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L  |
| Bacteriological Sample Collected: YESNO Results**:<br>(**Attach copy of results to record)   |
| Date / Time Water Main Returned to Service:am / pm   |
| Additional Comments:   |
| Rev 01-21-09   |

