## FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 8-22-13 Time: 10:00 Location: 190 Dowker Rd	
Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line	
NEW LINE INSTALLATION:  Were State approved or AWWA Standards Followed: (YES / NO)  Detailed summary of disinfection procedure used (Use back of page if needed):  8/23/13	7
Chlorine Residual Prior to Initial Flush: Length of Time of Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush:	
Water Supply (WS) Project Number:	
FOR LINE REPAIRS:	
Interruption of Water Service: YESNONumber of CustomersAffected:	
Main Size: 2" Poc Repaired Under Pressure: YES NO	
For partially or fully de-watered mains:	
Was positive pressure maintained while a trench was opened and area cleaned? (YES)  NO)  Time Water Main Valved Off (positive pressure removed): am / pm	
Nature of Leak or Break: leaking Plastic Securice	
Were State approved or AWWA Standards Followed: (YES)/NO) Replace with copper Detailed summary of repair procedure used (Use back of page if needed):	:6
Was water main contaminated during the repair process? (YES / NO)  Plushed like  Disinfection Procedure / Calculations (Use back of page if needed):	
Amount of Time Line Flushed: Minutes Ending Chlorine 7.20  Residual: mg/L	
Bacteriological Sample Collected: YESNO Results**:  (**Attach copy of results to record)	
Date / Time Water Main Returned to Service: am / pm	
Additional Comments:	
Rev 01-21-09 Adam Brett	

COPY

g 45 E-1

23. 3

-2 H - 1