

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 2-27-14 Time: 11:30 Location: 201 Emory Hts

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

COPY

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_

Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial

Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 1

Main Size: 3" Tens Repaired Under Pressure: YES ☐ NO ☐

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break: Bad saddle - pipe cracked at top

Were State approved or AWWA Standards Followed: (YES / NO) YES

Detailed summary of repair procedure used (Use back of page if needed):

Banded top  
Re-tapped

Was water main contaminated during the repair process? (YES / NO) NO

Disinfection Procedure / Calculations (Use back of page if needed):

Flushed line

Amount of Time Line Flushed: 1 Minutes

Ending Chlorine 2.20

Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES ☐ NO ☐

Results\*\*: \_\_\_\_\_

(\*\*Attach copy of results to record)

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

See Photos

Adam Jimmy

7 GPM Leak

Billy T.J.

COPY