

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 12-4-09 Time: 10 Am Location: 204 Emory St.

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

COPY

12/7/09

J

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed)

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected 2

Main Size: 4" Repaired Under Pressure: YES ☒ NO ☐

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES)
NO ☐

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break

Saddle broke

Were State approved or AWWA Standards Followed: (YES) NO ☐

Detailed summary of repair procedure used (Use back of page if needed):

Cleaned pipe + material with bleach then we flushed line + tied
service back together

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: _____ Minutes

Residual _____ mg/L

Ending Chlorine

Bacteriological Sample Collected: YES ☐ NO ☐

Results**: _____

(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

