

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

COPY

Date: 9-12-11 Time: 12:45 Location: 226 Virginia

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ___ NO ✓ Number of Customers Affected: _____

Main Size: 1" Galv Repaired Under Pressure: YES ___ NO ___

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

¹Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break:

hole in galv main

Were State approved or AWWA Standards Followed: (YES / NO)

Repaired with Band

Detailed summary of repair procedure used (Use back of page if needed):

Was water main contaminated during the repair process? (YES / NO)

Bleached Band

Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: _____ Minutes

Ending Chlorine

Residual: _____ mg/L

Bacteriological Sample Collected: YES ___ NO ___

Results**: _____

(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

See Photos

Aden - kin - Billy - Daniel

COPY