

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 8-15-16 Time: 4pm Location: 2356 Old Harrison Hwy

Please Circle Appropriate Action: NEW LINE INSTALLATION (LINE REPAIR)

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of disinfection procedure used (Use back of page if needed):

COPY

Date / Time of Initial Flush: Chlorine Residual after Flush:

Water Supply (WS) Project Number:

FOR LINE REPAIRS:

Interruption of Water Service: YES NO Number of Customers Affected:

Main Size: 8" Trans. Repaired Under Pressure: YES NO

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? YES NO

Time Water Main Valved Off (positive pressure removed): am / pm

Nature of Leak or Break: Corp blew out of Main

Were State approved or AWWA Standards Followed: YES NO Detailed summary of repair procedure used (Use back of page if needed): Cleaned pipe & clamp & put new saddle & corp on main.

Was water main contaminated during the repair process? YES NO Disinfection Procedure / Calculations (Use back of page if needed): Cleaned pipe & material with bleach.

Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L

Bacteriological Sample Collected: YES NO Results\*\*: (\*\*Attach copy of results to record)

Date / Time Water Main Returned to Service: 20 am / pm

Additional Comments:

YEPY

