

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 10-29-12 Time: 11:45 am Location: 322 Huse Watson Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)  
Detailed summary of disinfection procedure used (Use back of page if needed):

COPY  
10/29/12 J

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_  
Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial  
Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 1

Main Size: 2" PUC Repaired Under Pressure: YES ☐ NO ☒

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break: Leaking Blue May Service

Were State approved or AWWA Standards Followed: (YES / NO)  
Detailed summary of repair procedure used (Use back of page if needed):

Replaced with copper

Was water main contaminated during the repair process? (YES / NO) Flashed line  
Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: 1 Minutes  
Residual: \_\_\_\_\_ mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected: YES ☐ NO ☐  
(\*\*Attach copy of results to record)

Results\*\*: \_\_\_\_\_

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments: See Photos

Adam - Jimmy - Justin

