FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 8-7-14 Time: 10:30 - 3:00 Location: 330 school St
Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line
NEW LINE INSTALLATION:
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of disinfection procedure used (Use back of page if needed):
Chlorine Residual Prior to Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush:
Water Supply (WS) Project Number:
FOR LINE REPAIRS:
Interruption of Water Service: YES NONumber of CustomersAffected:
Main Size: 6" Repaired Under Pressure: YES NO
For partially or fully de-watered mains:
Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) Time Water Main Valved Off (positive pressure removed): am / pm
Nature of Leak or Break: Pin hole on plastic service
Were State approved or AWWA Standards Followed: (YES)/NO) Detailed summary of repair procedure used (Use back of page if needed): Killed old tap and Banded hole. made a new tap and replaced a 6' Piece of Plastic which made the service copper from tap to meter
Was water main contaminated during the repair process? (YES (NO)) Disinfection Procedure / Calculations (Use back of page if needed):
Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L
Bacteriological Sample Collected: YESNO Results**: (**Attach copy of results to record)
Date / Time Water Main Returned to Service: am / pm
Additional Comments:

Rev 01-21-09

COPY

a gitt to a siffer to record or a company on