

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 2-1-11 Time 3:00 p.m. Location 415 Baumgartner

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed)

COPY

2-1-11
J

Chlorine Residual Prior to Initial Flush

Date Time of Initial Flush Length of Time of Initial

Flush Chlorine Residual after Flush

Water Supply (WS) Project Number

FOR LINE REPAIRS:

Interruption of Water Service YES ☒ NO ☐ Number of Customers Affected 1

Main Size 6" Repaired Under Pressure YES ☒ NO ☐

For partially or fully de-watered mains

Was positive pressure maintained while a trench was opened and area cleaned? (YES ☒ NO ☐

Time Water Main Valved Off (positive pressure removed) am pm

Nature of Leak or Break

replacing service line and hit tap.

Were State approved or AWWA Standards Followed (YES ☒ NO ☐

Detailed summary of repair procedure used (Use back of page if needed)

Banded tap and made a new tap. Replaced service line

Was water main contaminated during the repair process? (YES ☒ NO ☐ Flushed line

Disinfection Procedure / Calculations (Use back of page if needed)

Amount of Time Line Flushed 1 Minutes
Residual mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected: YES ☐ NO ☐

Results**

(** Attach copy of results to record)

Date Time Water Main Returned to Service am pm

Additional Comments

See Photos

Aden - Bull - Kim

Over →

Leak had 14 GPM Before
18 GPM After

Booster tap closed for 2 hrs.

EH. running Gft out, one 4" outlet for 1 1/2 hrs.