

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 7-23-10 Time: 10:00 a.m. Location: 509 Cumberland St

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

COPY

Were State approved or AWWA Standards Followed: (YES / NO)
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: _____
Date / Time of Initial Flush: _____ Length of Time of Initial
Flush _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 1

Main Size: 6" cast Repaired Under Pressure: YES ☐ NO ☐

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break:

replaced leaking service, broke off top

Were State approved or AWWA Standards Followed: (YES) NO)
Detailed summary of repair procedure used (Use back of page if needed):

Replaced service

Was water main contaminated during the repair process? (YES / NO)
Disinfection Procedure / Calculations (Use back of page if needed): Flushed line

Amount of Time Line Flushed: 1 Minutes
Residual: _____ mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected: YES ☐ NO ☐ Results**: _____
(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

2' x 4' hole 10 sec to raise 6" for 1 hour

Y9