

# FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 9-10-13 Time: 9:45 Location: G44 Hesser Mill Rd

Please Circle Appropriate Action: New Line Installation / Line Repair Service Line

## NEW LINE INSTALLATION:

**COPY**

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

9/11/13

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_

Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial

Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

## FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 1

Main Size: 4" PUC Repaired Under Pressure: YES ☐ NO ☐

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

leaking plastic sewer

Were State approved or AWWA Standards Followed: (YES / NO) YES Replace with  
Detailed summary of repair procedure used (Use back of page if needed): Copper

Was water main contaminated during the repair process? (YES / NO) NO Flushed line  
Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: 1 Minutes  
Residual: \_\_\_\_\_ mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected: YES ☐ NO ☐  
(\*\*Attach copy of results to record)

Results\*\*: \_\_\_\_\_

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments: See Photos

2.5 GPM Leak

Adam - T.S. Jimmy

COPY