

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 6-25-13 Time: 9:00 AM Location: Airport Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES) ~~(NO)~~
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: _____
Date / Time of Initial Flush: _____ Length of Time of Initial
Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ____ NO ✓ Number of Customers Affected: 0

Main Size: 6" PVC Repaired Under Pressure: YES ✓ NO ____

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES) ~~(NO)~~

Time Water Main Valved Off (positive pressure removed): N/A am / pm

Nature of Leak or Break: split in pipe

Were State approved or AWWA Standards Followed: (YES) ~~(NO)~~
Detailed summary of repair procedure used (Use back of page if needed):

Bleached Band

Was water main contaminated during the repair process? (YES / (NO))
Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: _____ Minutes Ending Chlorine
Residual: _____ mg/L

Bacteriological Sample Collected: YES ____ NO ____ Results**: _____
(*Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

Donnie / Jimmy / James T / TJ

COPY

7-1-13

COPY