

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 7-21-13 Time: 0900 Location: Bowers Elem School

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

Taylor, West, Billy, James Hearn,
TJ

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed)

COPY

7/22/13 J

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 6

Main Size: 4" Cast Repaired Under Pressure: YES ☒ NO ☐

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES) / NO

¹Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break:

Crack in pipe

Were State approved or AWWA Standards Followed: (YES) / NO

Detailed summary of repair procedure used (Use back of page if needed):

Dug around & below pipe & cleaned

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Cleaned material with bleach & installed on main

Amount of Time Line Flushed: _____ Minutes

Ending Chlorine

Residual: _____ mg/L

Bacteriological Sample Collected: YES ☐ NO ☐

Results**: _____

(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

