

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 8/12/11 Time: _____ Location: Chambers RD.

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

COPY

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)
Detailed summary of disinfection procedure used (Use back of page if needed):

8-15-11
J

Chlorine Residual Prior to Initial Flush: _____
Date / Time of Initial Flush: _____ Length of Time of Initial
Flush: _____ Chlorine Residual after Flush: _____

30x 30

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ___ NO Number of Customers Affected: 0

Main Size: 2" PVC Repaired Under Pressure: YES NO ___

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES)
NO)

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break: 1/2" split in Main.

Were State approved or AWWA Standards Followed: (YES) NO)
Detailed summary of repair procedure used (Use back of page if needed):

Was water main contaminated during the repair process? (NO)
Disinfection Procedure / Calculations (Use back of page if needed):

Bleach on Band

Amount of Time Line Flushed _____ Minutes Ending Chlorine
Residual: _____ mg/L

Bacteriological Sample Collected: YES ___ NO ___ Results**:
(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments: