

# FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 4-21-11 Time: 2:30 <sup>pm</sup> Location: Martin Cir + Childs Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

## NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

COPY

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_

Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial

Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

## FOR LINE REPAIRS:

Interruption of Water Service: YES \_\_\_\_\_ NO ✓ Number of Customers Affected: 0

Main Size: 2" Poly Repaired Under Pressure: YES ✓ NO \_\_\_\_\_

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

Gasket in valve blown out

Were State approved or AWWA Standards Followed: (YES / NO) YES

Detailed summary of repair procedure used (Use back of page if needed): Cut Jet Valley Pump off and took valve apart and replaced gasket, shut incoming and outgoing valves.

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed): No, Had water coming out of valve while repairing

Amount of Time Line Flushed: \_\_\_\_\_ Minutes  
Residual: \_\_\_\_\_ mg/L

Ending Chlorine

Bacteriological Sample Collected: YES \_\_\_\_\_ NO \_\_\_\_\_  
(\*\*Attach copy of results to record)

Results\*\*: \_\_\_\_\_

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

See Photos

Adam Bull-Recd