FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 8/31/14 Time: -3/00 am Location: Emon & Walde St.
Please Circle Appropriate Action: New Line Installation (Line Repair / Service Line
NEW LINE INSTALLATION: T. J., Tay by, Dun
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of disinfection procedure used (Use back of page if needed):
Chlorine Residual Prior to Initial Flush: Date / Time of Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush:
Water Supply (WS) Project Number:
FOR LINE REPAIRS:
Interruption of Water Service: YES NONumber of CustomersAffected:
Main Size: Repaired Under Pressure: YES NO
For partially or fully de-watered mains:
Was positive pressure maintained while a trench was opened and area cleaned? (YES) NO) Time Water Main Valved Off (positive pressure removed): am / pm
Nature of Leak or Break: Split in 8" C.T
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of repair procedure used (Use back of page if needed): Cut out & Replaced 93'" Pipe
Was water main contaminated during the repair process? (YES (NO)) Disinfection Procedure / Calculations (Use back of page if needed): Switted fire with Bleach
Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L
Bacteriological Sample Collected: YESNO Results**: (**Attach copy of results to record)
Date / Time Water Main Returned to Service: am / pm
Additional Comments:

Rev 01-21-09