FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 6 29-11 Time: 11PM Location: Fairment Aug
Please Circle Appropriate Action: New Line Installation (Line Repair) Service Line
NEW LINE INSTALLATION:
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of disinfection procedure used (Use back of page if needed)
Chlorine Residual Prior to Initial Flush: Length of Time of Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush:
Water Supply (WS) Project Number:
FOR LINE REPAIRS:
Interruption of Water Service: YES NO Vumber of CustomersAffected:
Main Size: 216 Repaired Under Pressure: YESNO
For partially or fully de-watered mains:
Was positive pressure maintained while a trench was opened and area cleaned? (YES) NO) Time Water Main Valved Off (positive pressure removed): am / pm
Nature of Leak or Break:
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of repair procedure used (Use back of page if needed): Out below & around Pipe & Cleaned.
Was water main contaminated during the repair process? (YES / (10)) Disinfection Procedure / Calculations (Use back of page if needed): Cleaned pipe of material with Bleech.
Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L
Bacteriological Sample Collected: YES NO Results**: (**Attach copy of results to record)
Date / Time Water Main Returned to Service: am / pm
Additional Comments:

Rev 01-21-09