

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 7-17-17 Time: 9:30 Location: Frost Hollow Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

COPY

7/22/17

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 5

Main Size: 2" Poly Repaired Under Pressure: YES ☐ NO ☒

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

¹Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break: Leaking Butt Fuse

Were State approved or AWWA Standards Followed: (YES) / NO) Cut out fuse and replaced with Fusion Couplings

Was water main contaminated during the repair process? (YES / NO) Flushed line

Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: 20 Minutes
Residual: _____ mg/L

Ending Chlorine

Bacteriological Sample Collected: YES ☐ NO ☐
(**Attach copy of results to record)

Results**: _____

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments: See Photos

COPY