

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 11-13-12 Time: 9:30 am Location: Hannah Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

COPY

11/14/12

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)  
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_  
Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial  
Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

FOR LINE REPAIRS:

Interruption of Water Service: YES  NO  Number of Customers Affected: 1

Main Size: 4" PUC Repaired Under Pressure: YES  NO

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break: split in 4" PUC Main

Were State approved or AWWA Standards Followed (YES / NO) Replaced 3' section with knock-ons  
Detailed summary of repair procedure used (Use back of page if needed):

Was water main contaminated during the repair process? (YES / NO) Bleached pipe and knock-ons  
Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: \_\_\_\_\_ Minutes Ending Chlorine Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES  NO  Results\*\*: \_\_\_\_\_  
(\*Attach copy of results to record)

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments: See Photos

Rev 01-21-09

Throttled down Valve  
still had positive pressure on both ends

Adam  
Billy  
Dannic

COPY