## FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 5-27-19 Time:11: 30 Location:
Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line
NEW LINE INSTALLATION:
Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of disinfection procedure used (Use back of page if needed):
Chlorine Residual Prior to Initial Flush: Length of Time of Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush:
Water Supply (WS) Project Number:
FOR LINE REPAIRS:
Interruption of Water Service: YES NONumber of CustomersAffected:
Main Sizè: 6 Repaired Under Pressure: YES NO
For partially or fully de-watered mains:
Was positive pressure maintained while a trench was opened and area cleaned? (YES)  NO)  Time Water Main Valved Off (positive pressure removed): //:30 am/ pm
Nature of Leak or Break:  /esk & f @ Coupling (knock on coupling)
Were State approved or AWWA Standards Followed (YES NO)  Detailed summary of repair procedure used (Use back of page if needed):  Took Anock on Off and Replaced with a longer  knock on  Was water main contaminated during the repair process? (YES (NO))
Disinfection Procedure / Calculations (Use back of page if needed):
Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L
Bacteriological Sample Collected: YESNO Results**:  (**Attach copy of results to record)
Date / Time Water Main Returned to Service: PP98 5-27-14 12:30 am / pm
Additional Comments:
Rev 01-21-09

