

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 10-19-09 Time 3:30 PM Location Jasper Dr.

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed)

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial
Flush _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ____ NO ____ Number of Customers Affected ____

Main Size: _____ Repaired Under Pressure: YES ____ NO ____

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break: _____

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of repair procedure used (Use back of page if needed)

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed)

Amount of Time Line Flushed: _____ Minutes
Residual: _____ mg/L

Ending Chlorine _____

Bacteriological Sample Collected: YES ____ NO ____
(**Attach copy of results to record)

Results**: _____

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments: _____

COPY

Taylor, Reed
km, Darnie

