

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 9-13-12 Time: 10:00 a.m. Location: Lizzie Duncan Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)
Detailed summary of disinfection procedure used (Use back of page if needed):

COPY

9/18/12 J

Chlorine Residual Prior to Initial Flush: _____
Date / Time of Initial Flush: _____ Length of Time of Initial
Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ___ NO ✓ Number of Customers Affected: 0

Main Size: 2" PVC Repaired Under Pressure: YES ___ NO ✓

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break:

Leaking

Removed frost-free hydrant B.O. and put in metered B.O.

Were State approved or AWWA Standards Followed: (YES / NO) YES Replaced with copper
Detailed summary of repair procedure used (Use back of page if needed): and a meter.

Was water main contaminated during the repair process? (YES / NO) NO Flushed line
Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: 1 Minutes
Residual: _____ mg/L

Ending Chlorine 2.20

Bacteriological Sample Collected: YES ___ NO ___
(**Attach copy of results to record)

Results**: _____

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

See Photos

Rev. 01-21-09

Neighbor said been leaking over 3 months
Probably 5 GPM Leak

Adam
Kim
Bull

YCF. C