

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 11/16/12 Time: 1:30 PM Location: Pansey Hill (Gary Baker)

Please Circle Appropriate Action: New Line Installation (Line Repair) / Service Line

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ___ NO ✓ Number of Customers Affected: _____

Main Size: 1 1/4" Repaired Under Pressure: YES ✓ NO ___

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES)
NO)

Time Water Main Valved Off (positive pressure removed): N/A am / pm

Nature of Leak or Break

2 pen holes

Were State approved or AWWA Standards Followed: (YES) / NO)

Detailed summary of repair procedure used (Use back of page if needed):

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Bleach Band

Amount of Time Line Flushed: _____ Minutes

Ending Chlorine

Residual _____ mg/L

Bacteriological Sample Collected: YES ___ NO ___

Results**: _____

(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

Donny, Billy, Jimmy, Justin

COPY

11-19-12

