

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 10-7-13 Time: All Day Location: Pine Orchard Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

NEW LINE INSTALLATION:

COPY

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

10/8/13

Chlorine Residual Prior to Initial Flush: _____

Date / Time of Initial Flush: _____ Length of Time of Initial

Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES _____ NO ✓ Number of Customers Affected: 0

Main Size: 6" PVC Repaired Under Pressure: YES ✓ NO _____

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break: Bell Leaking

Were State approved or AWWA Standards Followed: (YES) / NO) Used Bell Repair
Detailed summary of repair procedure used (Use back of page if needed): Clamp

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: _____ Minutes
Residual: _____ mg/L

Ending Chlorine

Bacteriological Sample Collected: YES _____ NO _____
(**Attach copy of results to record)

Results**: _____

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments: See Photos

Adam
Drew - Billy

See Photos

COPY