FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

| Date: 6-5-12 Time: 6 6 3:00 P.M. Location: Pours Loop Rd |
|---|
| Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line |
| NEW LINE INSTALLATION: |
| Were State approved or AWWA Standards Followed: (YES / NO) Detailed summary of disinfection procedure used (Use back of page if needed): GOOD GOOD |
| Chlorine Residual Prior to Initial Flush: Length of Time of Initial Flush: Length of Time of Initial Flush: Chlorine Residual after Flush: |
| Water Supply (WS) Project Number: |
| FOR LINE REPAIRS: |
| Interruption of Water Service: YES NONumber of CustomersAffected: |
| Main Size: 2" Puc Repaired Under Pressure: YES_NO |
| For partially or fully de-watered mains: |
| Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) Time Water Main Valved Off (positive pressure removed): am / pm |
| Nature of Leak or Break: Split in 2" Put at Yaock-on |
| Were State approved or AWWA Standards Followed: (YES) NO) Replected 2 Section Detailed summary of repair procedure used (Use back of page if needed): With Knock-ons |
| Was water main contaminated during the repair process? (YES / NO) Bleaded pipe of Knock-c Disinfection Procedure / Calculations (Use back of page if needed): |
| Amount of Time Line Flushed: Minutes Ending Chlorine Residual: mg/L |
| Bacteriological Sample Collected: YESNO Results**: (**Attach copy of results to record) |
| Date / Time Water Main Returned to Service: am / pm |
| Additional Comments: Thiothed Uclue down |
| Additional Comments: Throttled Value down Rev 01-21-00 Had Positive Plessure on both ends See Photos Adam, Bull Kinn |
| See Photos Adam, Bull Kim |