

29

## FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 5-14-14 Time: 10:00 Location: Rankins ChapelPlease Circle Appropriate Action: New Line Installation / Line Repair / Service Line

COPY

## NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_

Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial

Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

## FOR LINE REPAIRS:

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 12Main Size: 4" PUL Repaired Under Pressure: YES ☐ NO ☒For partially or fully de-watered mains:Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

Split in 4" PUL mainWere State approved or AWWA Standards Followed: YES / NO Replaced 30ft  
Detailed summary of repair procedure used (Use back of page if needed): of mainWas water main contaminated during the repair process? (YES / NO) Bleached  
Disinfection Procedure / Calculations (Use back of page if needed): pipe & knock-onAmount of Time Line Flushed: 20 Minutes  
Residual: \_\_\_\_\_ mg/L

Ending Chlorine

Bacteriological Sample Collected: YES ☐ NO ☐  
(\*Attach copy of results to record)

Results\*\*: \_\_\_\_\_

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

See Photos

Adam

Jimmy

Billy

Taylor

COPY