

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 4-1-14 Time: 9:00 Location: Sexton loop By Press. Reducing
Pit

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

COPY

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: _____
Date / Time of Initial Flush: _____ Length of Time of Initial
Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ____ NO ☒ Number of Customers Affected: 0

Main Size: 4" Repaired Under Pressure: YES ☒ NO ____

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break:

Vacant service line was leaking

Were State approved or AWWA Standards Followed: (YES / NO)
Detailed summary of repair procedure used (Use back of page if needed):

Killed tap at main & put a cap on corporation

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: _____ Minutes
Residual: _____ mg/L

Ending Chlorine

Bacteriological Sample Collected: YES ____ NO ____
(**Attach copy of results to record)

Results**: _____

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments:

COPY