

# FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date 2/8/13 Time: 9:30 A.M Location: Snow Hill RD.

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

## NEW LINE INSTALLATION:

**COPY**

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_

Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial

Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

## FOR LINE REPAIRS:

Interruption of Water Service: YES \_\_\_\_\_ NO ☒ Number of Customers Affected: 0

Main Size: 6" PVC Repaired Under Pressure: YES ☒ NO \_\_\_\_\_

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) (YES)

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

Knock-on Coupling slid back and was leaking

Were State approved or AWWA Standards Followed: (YES) / NO

Detailed summary of repair procedure used (Use back of page if needed):

Dig below and around pipe. Cleaned everything and knocked coupling back on.

Was water main contaminated during the repair process? (YES / NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Positive Pressure was Maintained throughout process.

Amount of Time Line Flushed: \_\_\_\_\_ Minutes

Ending Chlorine

Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES \_\_\_\_\_ NO \_\_\_\_\_

Results\*\*: \_\_\_\_\_

(\*\*Attach copy of results to record)

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

15 GPM  
Hole size = 5 feet long  
2ft wide

100-100

