

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 12-16-13 Time: 12:05pm-2:30pm Location: state st

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

**NEW LINE INSTALLATION:**

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_

Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial

Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

**FOR LINE REPAIRS:**

Interruption of Water Service: YES \_\_\_ NO ✓ Number of Customers Affected: 0

Main Size: 4 inch Repaired Under Pressure: YES \_\_\_ NO \_\_\_

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) (YES)

<sup>1</sup>Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

leak at a union and small hole

Were State approved or AWWA Standards Followed: (YES) / NO)

Detailed summary of repair procedure used (Use back of page if needed):

installed 4 inch curb stop

Was water main contaminated during the repair process? (YES / NO) (NO)

Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: \_\_\_\_\_ Minutes

Ending Chlorine

Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES \_\_\_ NO \_\_\_

Results\*\*: \_\_\_\_\_

(\*\*Attach copy of results to record)

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

COPY