

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 1-3-2010 Time: 4:00pm Location: Gwa Pond Rd & Honeyuckle Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

Jeff, West,  
Bell, Daniel  
Adam

**NEW LINE INSTALLATION:**

Were State approved or AWWA Standards Followed: (YES / NO)

Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_

Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial

Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

**COPY**

1-4-10

Water Supply (WS) Project Number: \_\_\_\_\_

**FOR LINE REPAIRS:**

Interruption of Water Service: YES ☒ NO ☐ Number of Customers Affected: 5

Main Size: 2" Repaired Under Pressure: YES ☐ NO ☒

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO)

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

2" poly Fuse Broke

Were State approved or AWWA Standards Followed: (YES) / NO

Detailed summary of repair procedure used (Use back of page if needed):

2 2" MS Adaptors ? 12" Solid Sleeve Bleached All parts

Was water main contaminated during the repair process? (YES (NO))

Disinfection Procedure / Calculations (Use back of page if needed):

Amount of Time Line Flushed: 30 Minutes

Ending Chlorine

Residual: \_\_\_\_\_ mg/L

Bacteriological Sample Collected: YES ☒ NO ☐

Results\*\*: \_\_\_\_\_

(\*\*Attach copy of results to record)

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

COPY