

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 1-27-10 Time: 3:30 PM Location: Van Pk

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

COPY

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)  
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: \_\_\_\_\_  
Date / Time of Initial Flush: \_\_\_\_\_ Length of Time of Initial  
Flush: \_\_\_\_\_ Chlorine Residual after Flush: \_\_\_\_\_

Water Supply (WS) Project Number: \_\_\_\_\_

FOR LINE REPAIRS:

Interruption of Water Service: YES \_\_\_ NO ✓ Number of Customers Affected: 0

Main Size: 6" PVC Repaired Under Pressure: YES ✓ NO \_\_\_

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) YES

Time Water Main Valved Off (positive pressure removed): \_\_\_\_\_ am / pm

Nature of Leak or Break:

hole in 6" PVC

Were State approved or AWWA Standards Followed: YES / NO)  
Detailed summary of repair procedure used (Use back of page if needed):

Repaired with 6" x 7' Full Circle Band

Was water main contaminated during the repair process? (YES / NO)  
Disinfection Procedure / Calculations (Use back of page if needed):

Bleached Band

Amount of Time Line Flushed: \_\_\_\_\_ Minutes  
Residual: \_\_\_\_\_ mg/L

Ending Chlorine

Bacteriological Sample Collected: YES \_\_\_ NO \_\_\_  
(\*Attach copy of results to record)

Results\*\*: \_\_\_\_\_

Date / Time Water Main Returned to Service: \_\_\_\_\_ am / pm

Additional Comments:

2' x 4' hole

90 sec to raise 6"

