

FIELD DATA FOR NEW LINE INSTALLATION OR LINE REPAIR

Date: 6-27-12 Time: 3:00 Location: Webster Rd

Please Circle Appropriate Action: New Line Installation / Line Repair / Service Line

COPY
7/2/12

NEW LINE INSTALLATION:

Were State approved or AWWA Standards Followed: (YES / NO)
Detailed summary of disinfection procedure used (Use back of page if needed):

Chlorine Residual Prior to Initial Flush: _____
Date / Time of Initial Flush: _____ Length of Time of Initial
Flush: _____ Chlorine Residual after Flush: _____

Water Supply (WS) Project Number: _____

FOR LINE REPAIRS:

Interruption of Water Service: YES ___ NO ✓ Number of Customers Affected: 0

Main Size: 2" Galv Repaired Under Pressure: YES ✓ NO ___

For partially or fully de-watered mains:

Was positive pressure maintained while a trench was opened and area cleaned? (YES / NO) 0

Time Water Main Valved Off (positive pressure removed): _____ am / pm

Nature of Leak or Break: leak at 90° Bend

Were State approved or AWWA Standards Followed: (YES / NO) 0 Replaced with
Detailed summary of repair procedure used (Use back of page if needed): Brass and

Was water main contaminated during the repair process? (YES / NO) 0 Bends
Disinfection Procedure / Calculations (Use back of page if needed): Bleached Parts

Amount of Time Line Flushed: _____ Minutes Ending Chlorine
Residual: _____ mg/L

Bacteriological Sample Collected: YES ___ NO ___ Results**: _____
(**Attach copy of results to record)

Date / Time Water Main Returned to Service: _____ am / pm

Additional Comments: See Photos

Adam-Dominic-Bull-Billy-Taylor

COPY