



**NORFOLK
SOUTHERN**

Norfolk Southern Corporation
Transportation Department
South Main Street
Somerset, Kentucky 42501
606 679-8580



33

C. B. Bailiff
Superintendent

December 10, 1991
4-6-3

Mr. Donald Painter
Manager
Wolfe Branch Utility District
P. O. 325
Harriman, TN 37748

Dear Mr. Painter:

This refers to your application dated September 30, 1991 for a 12 inch water pipeline CNO&TP MP 254.0 near Oakdale, Tennessee.

Please revise plan and application to indicate end of casing being no nearer than 25 ft. from center line of track. Joints must be mechanical type for carrier pipe. Size of casing should be four inches larger than carrier pipe at its largest point (joint). It appears water line will parallel our tracks, on both sides, and distance should be shown for each side. Also, horizontal distance to nearest track at closest point. The right of way should also be shown and I attach a portion of our valuation map for this purpose.

Further consideration will be given your request upon receipt of revised plans and application.

Very truly yours,

C. B. Bailiff
Superintendent

HJS/sb

