

SECTION A-3

Scale: 1/4"=1'-0"

NOTE

SEE SPECIFICATIONS FOR LADDERS & MANHOLES REQ'D. FOR TANK



PLAN

Scale: 1/4"=1'-0"



NOTE

TANK, PIPING, FENCING, ACCESS & APPURTENANCES SHOWN AFTER STATION 49+37 SHALL BE INCLUDED IN THE LUMP SUM PRICE FOR BID ITEM 21

SITE PLAN

200,000 GALLON GROUND STORAGE TANK

Scale: 1"=20'

NOTES

1) ALL REINF. BARS TO HAVE A MIN. LAP OF 30 BAR DIA.
2) ALL REINF. BAR TO HOOK AROUND CORNERS A MIN. OF 30 BR. DIA.



TYPICAL SECTION THRU RING WALL

Scale: 1/2"=1'-0"



SECTION B-3

Scale: 3/8"=1'-0"





TELEMETRY VAULT

Scale: 1/4"=1'-0"



SECTION C-3

Scale: 3/8"=1'-0"



HEADWALL

N.T.S.



FENCE DETAIL

N.T.S.

POST HYDRANT ASSEMBLY

NOT TO SCALE

NOTES

1) ALL REINF. BARS TO HAVE A MIN. LAP OF 30 BAR DIA.
2) ALL REINF. BAR TO HOOK AROUND CORNERS A MIN. OF 30 BR. DIA.



TYPICAL REINF. AT CORNER OF RING WALL

Scale: 3/8"=1'-0"

ELROD · DUNSON, INC.
CONSULTING ENGINEERS
NASHVILLE, TENNESSEE

200,000 GALLON WATER STORAGE TANK & SITE PLAN

CITY OF HARRIMAN, WOLFE BRANCH UTILITY DIST.

MISCELLANEOUS DETAILS,

CONTRACT W93-01

REVISIONS

1. CHANGED CONTRACT TO W93-01
2. REMOVED REFERENCES TO CONTRACT W93-01 INCLUDED REFERENCES TO BID ITEM 21

8-12-93

DESIGNED
DRAWN
CHECKED
DATE MARCH, 1993
SCALE AS NOTED
PROJECT NO.

SHEET 1 B OF 2

DAZO SERVICE CO.